



1. THIS RISER DIAGRAM IS BASED ON A SIEMENS BUILDING TECHNOLOGIES XLS-250 FIREFINDER FIRE ALARM CONTROL PANEL OR APPROVED EQUAL. IT IS A REPRESENTATION OF THE INTENDED SYSTEM FOR THIS PROJECT. SEE THE FLOOR PLANS FOR QUANTITIES AND LOCATIONS OF FIELD EQUIPMENT. SEE THE PROJECT SPECIFICATIONS FOR PERFORMANCE AND COMPLIANCE REQUIREMENTS. QUANTITY AND SIZE OF CONDUCTORS TO BE DETERMINED BY FIRE ALARM SYSTEM SUPPLIER.
2. PROVIDE AUXILIARY FIRE ALARM SIGNAL PANEL(S) W/ BATTERY BACKUP AS REQUIRED TO SUPPORT NOTIFICATION APPLIANCE LOADS.
3. ALL WIRING REQUIREMENTS SHALL BE AS PER MANUFACTURER'S RECOMMENDATIONS.
4. ALL INSTALLED COMPONENTS TO FULLY COMPLY WITH APPLICABLE NFPA 72 REQUIREMENTS, LOCAL AND STATE CODES.
5. PROVIDE END OF LINE RESISTORS AS NECESSARY.
6. PROVIDE ADDRESSABLE MONITORING AND CONTROL MODULES AS RECOMMENDED BY FIRE ALARM SYSTEM SUPPLIER.
7. ALL ADDRESSABLE SLC'S SHALL BE NFPA 72 CLASS B, STYLE 4.
8. ALL NOTIFICATION NAC'S SHALL BE NFPA 72 CLASS B, STYLE Y.
9. STROBE SIGNALS MUST BE SIZED PER NFPA 72 REQUIREMENTS.
10. AUDIBLE NOTIFICATION DEVICES SHALL PROVIDE SOUND LEVEL AT LEAST 15dBA ABOVE AMBIENT NOISE LEVELS.
11. ALL PANEL BATTERY BACKUP SHALL BE SIZED AT 150% OF 24HR STANDBY PLUS 5 MINUTES OF ALARM.
12. A COMPLETE SET OF FIRE ALARM PRODUCT CUTSHEETS, FIRE ALARM SHOP DRAWINGS, AND BATTERY/ LOAD CALCULATIONS MUST BE SUBMITTED AND APPROVED PRIOR TO INSTALLATION.
13. CONTRACTOR SHALL ENGAGE THE SERVICES OF THE COUNTY FIRE ALARM VENDOR FOR PROGRAMMING AND CONNECTION TO THE COUNTY WIDE NETWORK.
14. SEE SHEET FA-100 FOR EQUIPMENT LEGEND.

SYSTEM INPUTS

FILE NO.: